



CERTIFICATE OF ASSESSMENT




Timber-framed floor/ceiling systems incorporating MiTek
PosiTruss joists with an FRL of 120/120/120

Client: Forest and Wood Products Australia

Job number: FAS190034 Issuing consultant: Imran Ahamed

Date: 6 September 2019 Revision: SFC1.0

Amendment schedule

Version	Date	Information relating to report			
SFC1.0	Issue: 06/09/2019	Reason for issue	Certificate issued to Forest and Wood Products Australia.		
			Prepared by	Reviewed by	Approved by
	Expiry: 31/07/2024	Name	Imran Ahamed	Mahmoud Akl	Kjetil Pedersen
		Signature			
	Issue:	Reason for issue			
			Prepared by	Reviewed by	Approved by
	Expiry:	Name			
		Signature			
	Issue:	Reason for issue			
			Prepared by	Reviewed by	Approved by
	Expiry:	Name			
		Signature			

Contact Information

Warringtonfire Aus Pty Ltd - ABN 81 050 241 524

NATA Registered Laboratory

Unit 2, 409-411 Hammond Road

Dandenong Victoria 3175

Australia

T: +61 (0)3 9767 1000

info.fire.melbourne@warringtonfire.com.au

Report sponsor	Certificate issue date	Product/system
Forest and Wood Products Australia	6 September 2019	MiTek PosiTruss joists

Introduction

The element of construction described below was assessed by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced Assessment Report(s) or Regulatory Information Report(s) for the complete description of the assessment construction.

Referenced assessment report	Test methods	Report issue date	Report validity date
FAS190034-R B1.0	AS 1530.4:2014	19 July 2019	31 July 2019

Description of assessment product and performance

The scope of the referenced assessment includes the fire resistance level (FRL) of timber-framed floor/ceiling systems incorporating Mitek PosiTruss joists when tested in accordance with AS 1530.4:2014.

Assessment outcome

FRL 120/120/120

RISF up to 120 minutes

Refer to the referenced report for a complete description of the assessed construction.

Conditions/ Validity

- This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance.
- Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
- The results of these fire tests may be used to assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all conditions.
- All work and services carried out by Warringtonfire Australia Pty Ltd ACN 050 241 524 are subject to, and conducted in accordance with, the standard terms and conditions of Warringtonfire Australia Pty Ltd, which are available at <https://www.element.com/terms/terms-and-conditions> or upon request.
- Exova Warringtonfire rebranded to Warringtonfire on 1 December 2018. Apart from the change to our brand name, no other changes have occurred. The introduction of our new brand name does not affect the validity of existing documents previously issued by us.